

<b>Subject:</b>	<b>SLEEPING AREAS</b>
<b>Section:</b>	<b>PPG# 4100.8</b>
<b>Chapter:</b>	<b>Operations</b>
<b>Effective Date:</b>	<b>7/1/98</b>

## **1.0 POLICY**

---

**1.1** All sleeping areas in fire stations shall be separated from vehicle storage areas by at least one-four fire resistive assemblies.

**1.2** Sleeping areas shall be protected by smoke detectors.

## **2.0 REFERENCES**

---

WAC 296-305-06507

[Statutory Authority: RCW 49.17.010, .050, .060. 96-11-067 (Order 94-27), §296-305-06507, filed 05/10/96, effective 01/01/97. Statutory Authority: Chapter 49.17 RCW. 88-14-108 (Order 88-11), 296-305-06507, filed 7/6/88.; Order 77-20, 296-305-06507, filed 10/18/77 and Emergency Order 77-24, filed 11/17/77, effective 12/17/77.]